

(1) Type Examination Certificate

(2) No. of the Type Examination Certificate: **ZP/B146/22** replaces ZP/B008/18

(3) Product: **Anchor device type A**
Type: **ABP-10-30**

(4) Manufacturer: **INNOTECH Arbeitsschutz GmbH**

(5) Address: **Laizing 10, 4656 Kirchham, Austria**

(6) The design of this product and any acceptable variation thereto are specified in the schedule to this Type Examination Certificate.

(7) The certification body of DEKRA Testing and Certification GmbH certifies that this product complies with the fundamental requirements of the standard listed under item 8 below. The examination and test results are set out in the report PB 22-159.

(8) The requirements of the standard are assured by compliance with

DIN EN 795:2012

DIN CEN/TS 16415:2017

ANSI/ASSE Z359.18:2017 Section 3.2.1


(9) This Type Examination Certificate relates only to the design, examination and tests of the specified product in accordance to the standard list. Further requirements of the Directive apply to the manufacturing process and supply of this personal protective equipment. These are not covered by this certificate.

(10) This Type Test Certificate is valid until 2027-10-24.

DEKRA Testing and Certification GmbH
Bochum, 2022-10-25

signed: Krökel
Managing director

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.


Managing director

TRANSLATION

- (11) Appendix to
- (12) **Type Examination Certificate**
ZP/B146/22
- (13) 13.1 Subject and Type
Anchor device type A
Type: ABP-10-30

13.2 Description

The anchor device of type ABP-10-30 (Fig. 1) is used to protect maximum three people against falls from a height. It consists of an angled cast-steel lug. The anchor device is assembled directly to the structure on suitable surfaces of sufficient strengths using the appropriate fasteners. The anchor device has a drill hole of \varnothing 35 mm which is used to secure the personal protective equipment against falls from a height. The drill hole has a diameter of \varnothing 17 mm and receives the fastener which is used to assemble the anchor device to the structure.

In addition, the anchor device can be used as an end or curve anchor in the system type ALLinONE of anchor device type C.



Fig. 1: Anchor device, type: ABP-10-30

- (14) Report
PB 22-159, 2022-10-25